

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7270-1496:141

Page 1 of 1

CATEGORY: Heat Detector

LISTEE: Firecom Inc., 39-27 59th Street, Woodside, NY 11377
Contact: Howard Kogen (718) 899-6100

DESIGN: Model F900-450 fixed temperature heat detector. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: Fixed Temperature: 135° F
Electrical: 17 - 28 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model designation, rating and UL label.

APPROVAL: Listed as fixed temperature heat detector for use with separately listed base (CSFM Listing No. 7300-1496:128) and fire alarm control unit.

XLF: 7270-1394:105

09-17-98



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

APRIL 22, 2002

*Listing Expires **June 30, 2003***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager